

Control Number: 50594



Item Number: 69

Addendum StartPage: 0



Public Utility Commission of Texas

Five-Year Report
Required by 16 Texas Admin. Code § 25.97(e)



PROJECT NO. 50594

AFFECTED ENTITY: City of College Station

General Information

Pursuant to 16 Texas Admin. Code § 25.97(e)(1), not later than May 1 every five years, each affected entity that owns or operates overhead transmission facilities greater than 60 kilovolts must submit this report. The first report must be submitted not later than May 1, 2020.

Instructions

Answer all questions, fill-in all blanks, and have the report notarized in the Affidavit.

Affidavit

A representative of the affected entity must swear to and affirm the truthfulness, correctness, and completeness of the information provided by attaching a signed and notarized copy of the Affidavit provided with this form.

Filing Instructions

Submit four copies (an original and three copies) of the completed form and signed and notarized Affidavit to:

Central Records Filing Clerk Public Utility Commission of Texas 1701 N. Congress Avenue P.O. Box 13326 Austin, Texas 78711-3326 Telephone: (512) 936-7180

Five-Year Report Form Last Updated in Project No. 49827

/

1. Historical five-year reporting period: 01/01/2014-12/31/2019				
What percentage of overhead transmission facilities greater than 60 kilovolts did you inspect for compliance with the National Electric Safety Code (NESC) relating to vertical clearance in the historical five-year reporting period?				
In 2012, College Station did a comprehensive Lidar evaluation of its transmission facilities greater than 60 kilovolts.				
In 2018, 26% of the transmission facilities greater than 60 kilovolts were flown with Lidar.				
In the historical five-year reporting period, College Station has inspected 100% of it's overhead transmission facilities greater than 60 kilovolts.				

Five-Year Report Form Last Updated in Project No. 49827

Affected Entity: City of College Station

PROJECT NO. 50594

2. Future five-year reporting period: 01/01/2020-12/31/2025 What percentage of overhead transmission facilities greater than 60 kilovolts do you anticipate you will inspect for compliance with the NESC relating to vertical clearance during the future five-year reporting period beginning on January 1 of the year in which this report is submitted?					

PROJECT NO. <u>50594</u>

Affected Entity: City of College Station

AFFIDAVIT

It swear or affirm that I have personal knowledge of the facts stated in this report or am relying on people with personal knowledge, that I am competent to testify to them, and that I have the authority to submit this report on behalf of the affected entity. I further swear or affirm that all statements made in this report are true, correct, and complete.

Signature Roy Cake, P.E.

Timothy R. Crabb Printed Name

Director of Electric Utility
Job Title

City of College Station
Name of Affected Entity

Sworn and subscribed before me this 1 day of May , 2020 .

Month Year

STACY LEE
ID #124165429
My Commission Expires
May 13, 2022

Notary Public in and For the State of Texus

My commission expires on May 13, 2022.